

Technical Compliance Report for supply of Refilling of Fire Extinguishers :

PROJECT: BMRCL

E Bid No-6300032703 dt: 22.05.2020

Total Qty in Nos : 300 Service required dt: 05.06.2020

SI No	Scope of Work:	Complied	Not Complied	Remarks
1	Fire extinguishers to be collected from Depots (Baiyappanahalli & Peenya BMRCL Depot, Bangalore) by Vendor.			
2	Re-filling of Fire-extinguishers to be done with suitable consumables (Powder & Nitrogen gas).			
3	Minimum of Two years Warranty to be provided after Re-filling. (Warranty stickers/labels to be applied on Fire Extinguishers)			
4	Thorough Inspection to be carried out by Vendor and if any components (i.e. Gasket, Valves, Gauges, Pins, Handle, Cylinder etc.,) requires replacement, the same to be replaced by vendor.			
5	Once the Re-filling is completed, the same has to be delivered at respective depots immediately.			
6	In case of any Malfunctioning / issues noticed during warranty period, vendor has to collect the Fire Extinguishers from respective depots and rectify the same and deliver back to respective depots at his cost.			

Firms sign with Seal